

# Environment Protection Licence Monitoring Data



Project Name: NorthConnex  
 Environment Protection Licence No: 20570  
 Link to Public Register on EPA website: [NorthConnex - EPL 20570](#)  
 Premise Address: BETWEEN WINDSOR ROAD, BAULKHAM HILLS & M2 MOTORWAY, PENNANT HILLS & M1 MOTORWAY WAHROONGA NSW 2076  
 Date Published: 13-February-2019  
 Monitoring Data for the Period: 01-January-2019 to 31-January-2019

Monitoring Type: Water Discharge Monitoring

EPL Discharge Point	Date Sampled	Date data obtained	Turbidity (NTU)		Total Suspended Solids (mg/L)		pH		Oil & Grease		Monitoring Frequency	Comments
			Licence Limit	Results	Licence Limit	Results	Licence Limit	Results	Licence Limit	Results		
Wilson WTP	01-Jan-19	01-Jan-19	50	n/a	50	<5	6.5 - 8.5	8.0	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	02-Jan-19	02-Jan-19	50	n/a	50	<5	6.5 - 8.5	7.7	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	03-Jan-19	03-Jan-19	50	n/a	50	<5	6.5 - 8.5	7.8	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	04-Jan-19	04-Jan-19	50	n/a	50	<5	6.5 - 8.5	7.8	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	05-Jan-19	05-Jan-19	50	n/a	50	<5	6.5 - 8.5	8.1	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	06-Jan-19	06-Jan-19	50	n/a	50	<5	6.5 - 8.5	8.0	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	07-Jan-19	07-Jan-19	50	n/a	50	<5	6.5 - 8.5	8.2	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
M120 - Westbound	08-Jan-19	08-Jan-19	50	48	50	n/a	6.5 - 8.5	8.5	None visible	None visible	Special Frequency 1	
M120 - RW B1	08-Jan-19	08-Jan-19	50	50	50	n/a	6.5 - 8.5	7.8	None visible	None visible	Special Frequency 1	
SC-01	08-Jan-19	08-Jan-19	50	34.7	50	n/a	6.5 - 8.5	8.1	None visible	None visible	Special Frequency 1	
NV01	08-Jan-19	08-Jan-19	40	11.8	50	n/a	6.5 - 8.5	8.2	None visible	None visible	Special Frequency 1	
Wilson WTP	08-Jan-19	08-Jan-19	50	n/a	50	<5	6.5 - 8.5	8.0	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	09-Jan-19	09-Jan-19	50	n/a	50	<5	6.5 - 8.5	7.9	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	10-Jan-19	10-Jan-19	50	n/a	50	<5	6.5 - 8.5	7.8	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report

mg/L = Milligrams per litre

NTU = Nephelometric Turbidity Unit

N/A = Not Applicable

NV = None Visible

DNS = Did Not Sample

# Environment Protection Licence Monitoring Data



Project Name: NorthConnex  
 Environment Protection Licence No: 20570  
 Link to Public Register on EPA website: [NorthConnex - EPL 20570](#)  
 Premise Address: BETWEEN WINDSOR ROAD, BAULKHAM HILLS & M2 MOTORWAY, PENNANT HILLS & M1 MOTORWAY WAHROONGA NSW 2076  
 Date Published: 13-February-2019  
 Monitoring Data for the Period: 01-January-2019 to 31-January-2019

Monitoring Type: Water Discharge Monitoring

EPL Discharge Point	Date Sampled	Date data obtained	Turbidity (NTU)		Total Suspended Solids (mg/L)		pH		Oil & Grease		Monitoring Frequency	Comments
			Licence Limit	Results	Licence Limit	Results	Licence Limit	Results	Licence Limit	Results		
Wilson WTP	11-Jan-19	11-Jan-19	50	n/a	50	<5	6.5 - 8.5	7.9	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	12-Jan-19	12-Jan-19	50	n/a	50	<5	6.5 - 8.5	7.9	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	13-Jan-19	13-Jan-19	50	n/a	50	<5	6.5 - 8.5	8.0	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
SC01	14-Jan-19	14-Jan-19	50	50	50	n/a	6.5 - 8.5	7.2	None visible	None visible	Special Frequency 1	
Wilson WTP	14-Jan-19	14-Jan-19	50	n/a	50	<5	6.5 - 8.5	8.1	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	15-Jan-19	15-Jan-19	50	n/a	50	<5	6.5 - 8.5	8.3	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	16-Jan-19	16-Jan-19	50	n/a	50	<5	6.5 - 8.5	8.2	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	17-Jan-19	17-Jan-19	50	n/a	50	<5	6.5 - 8.5	8.1	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	18-Jan-19	18-Jan-19	50	n/a	50	<5	6.5 - 8.5	7.5	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	19-Jan-19	19-Jan-19	50	n/a	50	<5	6.5 - 8.5	7.6	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	20-Jan-19	20-Jan-19	50	n/a	50	<5	6.5 - 8.5	7.7	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
NV01	21-Jan-19	21-Jan-19	40	17.6	50	n/a	6.5 - 8.5	7.7	None visible	None visible	Special Frequency 1	
Wilson WTP	21-Jan-19	21-Jan-19	50	n/a	50	<5	6.5 - 8.5	7.7	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report

mg/L = Milligrams per litre

NTU = Nephelometric Turbidity Unit

N/A = Not Applicable

NV = None Visible

DNS = Did Not Sample

# Environment Protection Licence Monitoring Data



Project Name: NorthConnex  
 Environment Protection Licence No: 20570  
 Link to Public Register on EPA website: [NorthConnex - EPL 20570](#)  
 Premise Address: BETWEEN WINDSOR ROAD, BAULKHAM HILLS & M2 MOTORWAY, PENNANT HILLS & M1 MOTORWAY WAHROONGA NSW 2076  
 Date Published: 13-February-2019  
 Monitoring Data for the Period: 01-January-2019 to 31-January-2019

Monitoring Type: Water Discharge Monitoring

EPL Discharge Point	Date Sampled	Date data obtained	Turbidity (NTU)		Total Suspended Solids (mg/L)		pH		Oil & Grease		Monitoring Frequency	Comments
			Licence Limit	Results	Licence Limit	Results	Licence Limit	Results	Licence Limit	Results		
Wilson WTP	22-Jan-19	22-Jan-19	50	n/a	50	<5	6.5 - 8.5	7.8	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
SC-03	23-Jan-19	23-Jan-19	50	3.3	50	n/a	6.5 - 8.5	8.2	None visible	None visible	Special Frequency 1	
Wilson WTP	23-Jan-19	23-Jan-19	50	n/a	50	<5	6.5 - 8.5	7.9	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
SC-01	24-Jan-19	24-Jan-19	50	35.5	50	n/a	6.5 - 8.5	7.9	None visible	None visible	Special Frequency 1	
M120 - RW B1	24-Jan-19	24-Jan-19	50	8.3	50	n/a	6.5 - 8.5	8.0	None visible	None visible	Special Frequency 1	
Wilson WTP	24-Jan-19	24-Jan-19	50	n/a	50	<5	6.5 - 8.5	8.0	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	25-Jan-19	25-Jan-19	50	n/a	50	<5	6.5 - 8.5	8.0	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	26-Jan-19	26-Jan-19	50	n/a	50	<5	6.5 - 8.5	8.1	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	27-Jan-19	27-Jan-19	50	n/a	50	<5	6.5 - 8.5	8.2	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	28-Jan-19	28-Jan-19	50	n/a	50	<5	6.5 - 8.5	8.0	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	29-Jan-19	29-Jan-19	50	n/a	50	<5	6.5 - 8.5	8.1	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	30-Jan-19	30-Jan-19	50	n/a	50	<5	6.5 - 8.5	7.9	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report
Wilson WTP	31-Jan-19	31-Jan-19	50	n/a	50	<5	6.5 - 8.5	8.0	None visible	None visible	Daily During Discharge	Full range of analysis to be included in 6 Monthly Water Monitoring Report

mg/L = Milligrams per litre

NTU = Nephelometric Turbidity Unit

N/A = Not Applicable

NV = None Visible

DNS = Did Not Sample