

# Environment Protection Licence Monitoring Data



Project Name: NorthConnex  
 Environment Protection Licence No: 20570  
 Link to Public Register on EPA website: [NorthConnex - EPL 20570](#)  
 Premise Address: BETWEEN WINDSOR ROAD, BAULKHAM HILLS & M2 MOTORWAY, PENNANT HILLS & M1 MOTORWAY WAHROONGA NSW 2076  
 Date Published: 12-September-2019  
 Monitoring Data for the Period: 01-August-2019 to 31-August-2019

Monitoring Type: Water Discharge Monitoring

EPL Discharge Point	Date Sampled	Date data obtained	Turbidity (NTU)		Total Suspended Solids (mg/L)		pH		Oil & Grease		Monitoring Frequency	Comments
			Licence Limit	Results	Licence Limit	Results	Licence Limit	Results	Licence Limit	Results		
Wilson WTP	09-Aug-19	09-Aug-19	50	N/A	50	5	6.5 - 8.5	6.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
SC01	19-Aug-19	19-Aug-19	50	20.3	50	N/A	6.5 - 8.5	7.9	None visible	None visible	Special Frequency 1	
Wilson WTP	23-Aug-19	23-Aug-19	50	N/A	50	5	6.5 - 8.5	6.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	24-Aug-19	24-Aug-19	50	N/A	50	5	6.5 - 8.5	6.5	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	25-Aug-19	25-Aug-19	50	N/A	50	6	6.5 - 8.5	7.1	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	26-Aug-19	26-Aug-19	50	N/A	50	5	6.5 - 8.5	7.1	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	27-Aug-19	27-Aug-19	50	N/A	50	5	6.5 - 8.5	6.5	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	28-Aug-19	28-Aug-19	50	N/A	50	5	6.5 - 8.5	7.3	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	29-Aug-19	29-Aug-19	50	N/A	50	5	6.5 - 8.5	7.3	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	30-Aug-19	30-Aug-19	50	N/A	50	5	6.5 - 8.5	6.5	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	31-Aug-19	31-Aug-19	50	N/A	50	<5	6.5 - 8.5	6.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling

mg/L = Milligrams per litre

NTU = Nephelometric Turbidity Unit

N/A = Not Applicable

NV = None Visible

DNS = Did Not Sample