

# Environment Protection Licence Monitoring Data



Project Name: NorthConnex  
 Environment Protection Licence No: 20570  
 Link to Public Register on EPA website: [NorthConnex - EPL 20570](#)  
 Premise Address: BETWEEN WINDSOR ROAD, BAULKHAM HILLS & M2 MOTORWAY, PENNANT HILLS & M1 MOTORWAY WAHROONGA NSW 2076  
 Date Published: 08-January-2020  
 Monitoring Data for the Period: 01-December-2019 to 31-December-2019

Monitoring Type: Water Discharge Monitoring

EPL Discharge Point	Date Sampled	Date data obtained	Turbidity (NTU)		Total Suspended Solids (mg/L)		pH		Oil & Grease		Monitoring Frequency	Comments
			Licence Limit	Results	Licence Limit	Results	Licence Limit	Results	Licence Limit	Results		
Wilson WTP	01-Dec-19	01-Dec-19	50	N/A	50	<5	6.5 - 8.5	7.0	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	03-Dec-19	03-Dec-19	50	N/A	50	<5	6.5 - 8.5	6.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
MT K Basin	04-Dec-19	04-Dec-19	40	4.3	40	N/A	6.5 - 8.5	7.5	None visible	None visible	Special Frequency 1	
Wilson WTP	04-Dec-19	04-Dec-19	50	N/A	50	<5	6.5 - 8.5	6.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	05-Dec-19	05-Dec-19	50	N/A	50	<5	6.5 - 8.5	6.7	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	06-Dec-19	06-Dec-19	50	N/A	50	<5	6.5 - 8.5	6.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	07-Dec-19	07-Dec-19	50	N/A	50	<5	6.5 - 8.5	6.7	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	08-Dec-19	08-Dec-19	50	N/A	50	<5	6.5 - 8.5	6.8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
SC01	09-Dec-19	09-Dec-19	50	21.8	50	N/A	6.5 - 8.5	8.4	None visible	None visible	Special Frequency 1	
Wilson WTP	09-Dec-19	09-Dec-19	50	N/A	50	<5	6.5 - 8.5	6.8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	11-Dec-19	11-Dec-19	50	N/A	50	<5	6.5 - 8.5	6.8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	12-Dec-19	12-Dec-19	50	N/A	50	<5	6.5 - 8.5	6.6	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	13-Dec-19	13-Dec-19	50	N/A	50	<5	6.5 - 8.5	6.8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	16-Dec-19	16-Dec-19	50	N/A	50	<5	6.5 - 8.5	6.8	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling

mg/L = Milligrams per litre

NTU = Nephelometric Turbidity Unit

N/A = Not Applicable

NV = None Visible

DNS = Did Not Sample

# Environment Protection Licence Monitoring Data



Project Name: NorthConnex  
 Environment Protection Licence No: 20570  
 Link to Public Register on EPA website: [NorthConnex - EPL 20570](#)  
 Premise Address: BETWEEN WINDSOR ROAD, BAULKHAM HILLS & M2 MOTORWAY, PENNANT HILLS & M1 MOTORWAY WAHROONGA NSW 2076  
 Date Published: 08-January-2020  
 Monitoring Data for the Period: 01-December-2019 to 31-December-2019

Monitoring Type: Water Discharge Monitoring

EPL Discharge Point	Date Sampled	Date data obtained	Turbidity (NTU)		Total Suspended Solids (mg/L)		pH		Oil & Grease		Monitoring Frequency	Comments
			Licence Limit	Results	Licence Limit	Results	Licence Limit	Results	Licence Limit	Results		
SC01	18-Dec-19	18-Dec-19	50	11.2	50	N/A	6.5 - 8.5	6.7	None visible	None visible	Special Frequency 1	
Wilson WTP	18-Dec-19	18-Dec-19	50	N/A	50	<5	6.5 - 8.5	6.7	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling
Wilson WTP	19-Dec-19	19-Dec-19	50	N/A	50	<5	6.5 - 8.5	6.7	None visible	None visible	Daily During Discharge	Full range of analysis reporting against Monthly Surface Water Sampling

mg/L = Milligrams per litre

NTU = Nephelometric Turbidity Unit

N/A = Not Applicable

NV = None Visible

DNS = Did Not Sample